



Department of Utilities 10455 Armstrong Street Fairfax, VA 22030-3630


CITY of FAIRFAX

USE WITH THE FAIRFAX STANDARD SPECIFICATIONS ONLY

Voice (703) 385-7920 FAX (703) 934-8427 www.fairfaxva.gov

4' DIAMETER MANHOLE FLAT TOP

SCALE: Not To Scale	DETAIL# 2532.02



NOTES:

- 1. Concrete strength to be 4,000 PSI minimum.
- 2. Pipes will be grouted inside and out.
- 3. Flexible sleeve boots cast in place or installed with stainless steel expander rings. Boots to meet ASTM C-923 standards.
- 4. See detail 532.03 for invert shaping.
- 5. All service laterals into manhole to be core drilled and booted.
- 6. Maximum depth 4' diameter manhole = 20' (see sewer design section for other requirements / limitations).
- 7. When directed by the engineer, place manhole insert such as "no-flow/inflow" insert or "rainstopper" insert as manufactured by "Southwestern Packing & seals" or approved equal.
- 8. For watertight applications, place butyl rubber between frame and cone. Bolt frame to cone.
- 9. See detail 532.07 for manhole base larger than 4' diameter.



Department of Utilities 10455 Armstrong Street Fairfax, VA 22030-3630 **CITY of FAIRFAX**

USE WITH THE FAIRFAX STANDARD SPECIFICATIONS ONLY

Voice (703) 385-7920 FAX (703) 934-8427 www.fairfaxva.gov

4' DIAMETER MANHOLE FLAT TOP

SCALE:	DETAIL#
Not To Scale	2532.02
REVISION DATE:	SHEET #:
July, 2005	2 of 2